





Wall Thickness and RF Penetrations

T.Sanami (KEK)





ML simulation model

Plan view




Cross section







Dose rate for dark current (Access)


Normal loss : 6.875e10eps (50nA eq.) due to dark current






Dose rate for Dark current (Waveguide)


Normal loss : 6.875×10^{10} eps (50nA eq.) due to dark current







Dose rate for Dark current (Waveguide)

Normal loss : 6.875×10^{10} eps (50nA eq.) due to dark current





Conclusion

- Thickness of Shield wall to protect personnel from dark current, including access between tunnels and cable and RF penetrations
 - *Access between tunnels, Plan A*
 - *RF penetration. No cable penetration*
 - *Evaluated under ML shield wall of 1.5 m in thickness*
- Things to do
 - *Make a list of penetrations, interval, diameter and filled material, design access between two areas*
 - *Find a place to confirm simulation results*